


雨覆(JCAA D-016)



型 番	種 別	各 部 の 寸 法 (mm)						
		d	D	L	M	N	P	T
HA-51	A	12	80	110	50	60	10	3
	B	15	80	100	40	60	10	3
	C	17	80	90	30	60	10	3
	D	20	80	80	20	60	10	3
HA-52	A	23	105	125	55	70	10	4
	B	26	105	115	45	70	10	4
	C	29	105	105	35	70	10	4
	D	32	105	95	25	70	10	4
HA-53	A	36	145	145	60	85	10	5
	B	41	145	135	50	85	10	5
	C	45	145	125	40	85	10	5
	D	50	145	115	30	85	10	5
HA-54	A	55	185	170	70	100	10	5
	B	60	185	160	60	100	10	5
	C	65	185	150	50	100	10	5
	D	70	185	140	40	100	10	5

〈雨覆選定表〉 ※作業時にケーブルサイズ別にA～Dに合わせて御使用下さい(B、C、Dは切断)。

ケーブル導体断面積 (mm ²)	3300V	6600V	11kV
14	HA-51B	HA-51C	HA-51D
22		HA-51D	
38	HA-51C		
60	HA-51D	HA-52A	
100	HA-52A	HA-52B	HA-52B
150	HA-52B	HA-52C	HA-52C
200	HA-52C	HA-52D	HA-52D
250	HA-52D	HA-53A	HA-53A
325	HA-53A	HA-53B	
400	HA-53B		
500		HA-53C	
600	HA-53C	HA-53D	HA-53C
800	HA-53D	HA-54A	HA-53D
1000	HA-54A	HA-54B	HA-54A